



Government

Related Document: [hyperlink to Workplace Hazard Identification](#)

**Fire Extinguisher**

Hazard Identification Template

Reference: GAM 3.48, Standard A

Corporate Bank: Health and Safety

**Location of Fire Extinguisher in the building or vehicle #:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Inspected by (print name(s)):** \_\_\_\_\_

**Review by Supervisor of Work Area:** \_\_\_\_\_  
(upon completion of initial inspection) (print name) (signature) (date)

**Review by Supervisor of Work Area:** \_\_\_\_\_  
(confirms mitigation of hazards) (print name) (signature) (date)

**Review by Joint Health Safety Committee or Safety Representative:** \_\_\_\_\_  
(print name of co-chair/safety representative) (signature) (date)

Category	Y E S		N O		Corrective Action Required (include exact location of hazard)	Employee Assigned To Correct	Date Complete	Additional Comments
Fire Extinguisher								
Serial Number:								
Is it free and clear for easy access?								
<b>Base of Extinguisher:</b> Is it free of: corrosion? puncture marks?								



Government

**Fire Extinguisher**

Hazard Identification Template

Reference: GAM 3.48, Standard A

**Related Document:** [hyperlink to Workplace Hazard Identification](#)

Corporate Bank: Health and Safety

Is the tag securely attached to it showing: maintenance date? recharge date? servicing agency? signature of the person who performed the service?						
<b>Gauge:</b> Is the needle in the green area? If not requires to be pulled out of service						
Is the pin secure at the top?						
Is the lable clear and easy to read?						
Are the directions on how to operate the fire extinguisher attached?						
Have you turned the extinguisher up and down to move powder around?						
Is the "ABC" Fire Extinguisher located in the area and labelled properly?						
Is the fire extinguisher mounted 4"-42" above floor level and fastened securely to wall?						
Has the fire extinguisher been serviced every year by a certified company?						